

## Bettis Tribble Gap Gravity Sewer RFI

Last Updated 4/24/2025

### Questions:

1. The Bid Item #1 under Miscellaneous Work, Class "A" Pavement Replacement has a Unit for SY but no quantity? What is the quantity for this line item?
  - a. 420 SY
2. Temporary Stream Crossing detail on Sheet C5-03 says "Minimum pipe diameters sized as specified in "Pipe Diameters for Stream Crossings"" but there is no detail or section showing those sizes for creek crossing. Where is the detail for this?
  - a. Use 2 – 36" pipes